

**CERTIFICATE OF CONFORMANCE
N-BUTANE
R-600 REFRIGERANT GRADE**



Guaranteed Specifications

Minimal Purity

99.5 % +

n-Butane

99.50 % +

Sum of all impurities to

Ethane

18 PPM

be < 0.50 %

Isobutane

< 1500 PPM

Water < 5 PPM

Propane

< 20 PPM

Isopentane

< 20 PPM

Liquid Phase Analysis

Neo-pentane

< 550 PPM

Water

< 5 PPM

Oxygen

< 2 PPM

Nitrogen

< 10 PPM

Sulfur

Non Detected

Certified by: _____

Date: _____

SO# 000

Cylinder Serial Number(s)

Batch Number